

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 32

Dated: 27/7/24

It is certified that an inspection team headed by Satya Prakash Azad

(Name of Officers with designation) from RWTL Muzaffarpur PHED

inspected the S.L. Mary International School Bangra Handas

(Name & Address of the school) on 20/7/2024 (date of inspection) and on the basis of Kudhoni Muzaffarpur

Water Test Report (Attached) bearing no. 150 dated 20/7/2024

of RWTL Muzaffarpur (PHED Lab) certified that the

S.L. Mary International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 4/1/2025

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : P.H.E.D.,

Muzaffarpur  
Executive Engineer  
P. H. Divn. Muzaffarpur

Mukesh Kumar  
Executive Engineer

To S.L. Mary International School  
Bangra Handas Kudhoni Muzaffarpur  
(Name & Address of the Institution)

MUZAFFARPUR  
841001

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**PUBLIC HEALTH ENGINEERING DEPARTMENT**

**Water Quality Report**

**Division Name :- P. H. Division, Muzaffarpur**

**District Name : Muzaffarpur**

**Month : July 2024**

**Name of the School :- S.L Mary International SCHOOL, MUZAFFARPUR**


Sl. No.	Testing Date	Block	Panchayat	Village	Habitation/ Ward	Location of Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	No <sub>3</sub>	So <sub>4</sub>	F	As	Total Cell	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	11.07.2024	Kurhani	Kuarhani	Bangra Hardas	-	S.L Mary Bangra Hardas, Kurhani Muzaffarpur	6.86	1.2	196	128	113.2	25.2	14.7	15.84	112	0.2	0.1	5	BDL	-	-	
Desirable Limit **							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	BDL	0.01	-	
Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision)							NR	5.0		2000	600	200	100	1000	600	1	NR	400	1.5	NR	-	

Note: (1) Drinking Water Specification First Revision -IS:10500:2012, Edition 2.2(2003-09,12,20)(Reaffirmed1993), (2) BDL = Below Detection Limit, (3)NR = No Relaxation, (4) ND = Not Done.

(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml,

(c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Copy forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt. of Bihar, (ii) Director, Water Quality Cell, PHED, Govt. of Bihar, (iii) SLWTL, PHED, Govt. of Bihar.


  
**CHEMIST**  
 R.W.T.L. MUZAFFARPUR